

## DISTRICT WATER TESTING LABORATORY, MANSA

Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa  
dwtlmansa@gmail.com

To,

NOOR VATIKA ENGLISH SCHOOL, GAMIWALA  
NEAR RADHA SOAMI SATSANG GHAR, RATIA ROAD, GAMIWALA, MANSA


No.: DWTL/MNS/2425/00041      Dated : 24/05/2024

Subject :      Testing Reports of Water Samples.


Reference:      Your Letter/SRF No. 477/2024      Dated: 13/05/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 13/05/2024. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Mansa

D/A :      Test Report



Authorized Signatory  
For, District Water Testing Laboratory  
Mansa

  
Secretary  
Shaheed Baba Dhana Singh  
Education & Research Society  
Village Gamiwala (Mansa)

  
Principal  
Noor Vatika English School  
Gamiwala (Mansa)



# DISTRICT WATER TESTING LABORATORY, MANSA

Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa  
dwtlmanisa@gmail.com



## TEST REPORT

Name & Address of Customer : <b>NOOR VATIKA ENGLISH SCHOOL,GAMIWALA NEAR RADHA SOAMI SATSANG GHAR,RATIA ROAD,GAMIWALA,MANSA</b>		Customer Reference No.	<b>No : 477/2024 Dated : 13/05/2024</b>
		Sample Submitted by	<b>MR.HARPINDER SINGH</b>
		Date of Sample Receipt	<b>13/05/2024</b>
		Analysis Starting Date	<b>20/05/2024</b>
		Analysis completion Date	<b>21/05/2024</b>
Discipline : <b>Chemical Testing</b>		Group: <b>Water</b>	
ULR No.:	<b>TC000124000000087F</b>	Sample Type :	<b>Water</b>
Test Report No.:	<b>DWTL/MNS/2425/00041</b>	Date of Issue :	<b>24/05/2024</b>
Registration no.:	<b>DWTL/MNS/REG2425/00157</b>	Condition of Sample :	<b>Unsealed</b>
Collection Point:	<b>Treatment Plant (RO/CWPP/ARP/HH Purifier)</b>	Quantity/Type of Bottle:	<b>500 ml / Transparent Plastic Bottle</b>
Scheme/Source:	<b>Not Mentioned(Not Mentioned)</b>	Location/Depth :	<b>N.V.E.SCHOOL, NEAR RADHA SOAMI SATSANG GHAR,RATIA ROAD,GAMIWALA / NA</b>
Village :	<b>Gamiwala</b>	Habitation :	<b>Gamiwala</b>
Block:	<b>Budhlada</b>	District :	<b>Mansa</b>
Latitude :	<b>Not Mentioned</b>	Longitude:	<b>Not Mentioned</b>

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.95@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electro-metric Method
2	Colour	05	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	AGREEABLE	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	AGREEABLE	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	400	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.51	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	168	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	208	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium(Ca)	20.84	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium(Mg)	37.90	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	51.98	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

**Principal**  
**Noor Vatika English School**  
**Gamiwala (Mansa)**

**Secretary**  
**Shaheed Baba Dhana Singh**  
**Education & Research Society**  
**Village Gamiwala (Mansa)**

**Reviewed and Approved By**

**Komal Sharma**

**Ms. Komal Sharma**  
**Quality Manager**  
**Authorized Signatory**  
**For, District Water Testing Laboratory**  
**Mansa**

End of the Test Report



PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.


No. 548/2024Date : 11/11/24

It is certified that an inspection team headed by Medical officer (Name of Officers  
with designation) from SDM Guahlada (Name of  
Department/Office) inspected the Noor Vatika English  
School Gamiwala (Name & Address of  
the School) on 11/11/24 and found that the Noor Vatika  
English school (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year.Signature with Seal : [Signature]

Name

Designation



To

Noor Vatika English School  
Vill. Gamiwala, Mansa

(Name &amp; Address of the Institution)

Principal  
Noor Vatika English School  
Gamiwala (Mansa)

Secretary  
Saba Dhana Singh  
& Research Society  
Gamiwala (Mansa)

Headmaster / Head  
Noor Vatika English School  
Gamiwala (Mansa)